


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Director: Dr. Thomas-Benjamin Seiler

Legal Entity: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:

Rotthauer Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0

Telefax +49 (0)209 9242-222

Internet www.hyg.de

E-Mail: klimatechnik@hyg.de

Our reference: W-343087-21-Zd

Contact person: Dipl.-Ing. (FH) S. Horn
B. Zeidler

Gelsenkirchen, 07.05.2021

Test - certificate

hygiene-conformity check to the design requirements
of selected regulations

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
45879 Gelsenkirchen

Test object: Counterflow heat exchangers
RS 160, RS 220, RS 300
RC 160, RU 160

Manufacturer: Recair BV
Spuiweg 28
NL – 5145 Waalwijk

Basis of the examination: ✓ VDI 6022, sheet 1 (01/2018)
✓ ÖNORM H 6021 (08/2016)
✓ SWKI VA104-01 (01/2019)

Validity period: 5 years 05/2021 – 05/2026

Test report: W-343087-21-Zd

In conclusion it can be stated that the examined Counterflow heat exchangers RS 160, 200, 300, RC 160, RU 160, as specified in the test report W-343087-21-Zd, is in compliance with the above mentioned regulations.

(Dipl.-Ing. (FH) S. Horn)
Head of the Department hygienic building technology

(B. Zeidler)
clerk of the Department hygienic building technology

issued 07.05.2021, Gelsenkirchen



Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.